Evette Yu 600 108th Ave NE Bellevue, WA 98004

Re: Project #3037857-LU

Correction Notice #1

Owner Shuang Zhang

Date July 06, 2021 **Contact Phone** (425) 559-7584

Address Seattle Department of Construction and Inspections
700 Fifth Ave
Suite 2000

Seattle, WA 98124-4019

PO Box 34019

Applicant Instructions

You will not be able to upload corrected plans until all reviews are completed and the project's review status is "Corrections Required".

*** Respond by providing a written response to each correction AND identify changes to drawings since initial review. ***

Drawings shall be **legible**, with sheets **oriented correctly**, on an appropriate **sheet size**, with all revisions/changes **clouded or circled**, with **no missing sheets**, and uploaded in a **single PDF file**.

Link for detailed steps: "How to Respond to a Correction Notice". If the 3-step process outlined in this document is not followed, your response could be **rejected**, permit issuance could be **delayed**, and **penalty fees** could be assessed.

Codes Reviewed

This project has been reviewed for conformance with Seattle City Light Construction Standard D2-3.

Corrections

1. City Light Engineering has reviewed plans and cannot determine if the proposed building meets minimum clearance requirements from 26kV overhead high voltage lines (HVL) and open supply conductors along NW 36th St. Additional information is needed. Please show the property lines on both east and west elevation drawings.

Per SCL Construction Standard D2-3, fourteen (14) feet radial clearance is required between power lines, open supply conductors, and any part of the permanent structure (http://www.seattle.gov/light/engstd/docs2/d2-3.pdf).

This review is for clearance only. It is not a review or approval for electrical service to the site. A separate service application to City Light is required.

Project #3037857-LU, Correction Notice #1